




Middle School – High School Study for:
Alden-Hebron School District #19





ALDEN-HEBRON SCHOOL DISTRICT #19





Demolition Budget
\$465,000.00

Asbestos
Abatement Budget
\$75,000

McKinley Ave

McKinley Ave

McKinley Ave

St Albans St

St Albans St

47

Main St

Price Rd

Price Rd

Price Rd


Price Rd

Alden Hebron
District #19

Triseal Corp



BRADLEY AND BRADLEY
— ARCHITECTS —



Conceptual Floor Plan



Project Location:

Alden - Hebron Community Unit School District 19



Date: Friday, November 24, 2017
Tuesday, May 8, 2018
Monday, June 25, 2018

Fire Protection System, in addition to water system in OPC

Item	Unit	Quantity	Unit Cost	Total Cost
Fire Protection				
Pressure tank 2 Hour Supply, 5,000 gallon pressure tank	LUMP SUM	1	\$ 80,000.00	\$ 80,000.00
Storage Tank , estimate 60,000 gallons	Gallons	60000	\$ 1.25	\$ 75,000.00
Excavation (haul-off) from tank	Cu Yds	1500	\$ 30.00	\$ 45,000.00
Emergency Generator, natural gas fired with pad and controls	LUMP SUM	1	\$ 35,000.00	\$ 35,000.00
Fire Pumps, suction from tank storage, supply to sprinkler heads in school	Each	2	\$ 12,000.00	\$ 24,000.00
Water Softener, filters, plumbing	LUMP SUM	1	\$ 20,000.00	\$ 20,000.00
Pump house, 60' x 24' prefabricated building	Each	1	\$ 15,000.00	\$ 15,000.00
Total				\$ 294,000.00

